



Sample image

CA50

Type Size: S1

Classification Contact: Rigid contact bridge

Classification Contact Mat: Silver

Classification Terminal: Screw terminal

IEC 60947-3 EN 60947-3, VDE 0660 Teil 107

Rated insulation voltage Ui

Voltage (V)	AC / DC
690	AC

Rated impulse withstand voltage Uimp

Voltage (kV)	Overtoltage category	Pollution degree	Supply system	Function
6	III	3	Valid for lines with grounded common neutral termination	Switch / Switch disconnector

Rated uninterrupted current Iu/Ith

Current (A)	Ambient temperature (°C)	Peak temperature (°C)	additional requirements
50	55	60	Ambient temperature +55°C during 24 hours with peaks up to +60°C

Conventional enclosed thermal current Ithe

Current (A)	Ambient temperature (°C)	Peak temperature (°C)	Additional requirements	No. of stages (from - to)	Mounting	Mounting size
50	35	40	Ambient temperature +35°C during 24 hours with peaks up to +40°C	--	--	--

Rated operational current Ie

Utilization category	Voltage (V)	Current (A)
AC-15	220 - 240	16
AC-15	380 - 440	7
AC-20A	690	50
AC-21A	20 - 690	50
AC-22A	20 - 690	50

Rated operational power

Utilization category	Voltage (V)	No. of phases	No. of poles	Power (kW)
AC-2	220 - 240	3	3	11
AC-2	380 - 440	3	3	22
AC-2	500 - 500	3	3	30
AC-2	660 - 690	3	3	30
AC-3	220 - 240	3	3	11
AC-3	380 - 440	3	3	18,50
AC-3	500 - 500	3	3	18,50
AC-3	660 - 690	3	3	18,50
AC-3	110 - 120	1	2	3
AC-3	220 - 240	1	2	6
AC-3	380 - 440	1	2	11
AC-3	500 - 500	1	2	15
AC-3	660 - 690	1	2	11
AC-4	220 - 240	3	3	4
AC-4	380 - 440	3	3	7
AC-4	500 - 500	3	3	7
AC-4	660 - 690	3	3	7,50
AC-4	110 - 120	1	2	1,20
AC-4	220 - 240	1	2	2,40
AC-4	380 - 440	1	2	4
AC-23A	220 - 240	3	3	11
AC-23A	380 - 440	3	3	22
AC-23A	500 - 500	3	3	22
AC-23A	660 - 690	3	3	22
AC-23A	110 - 120	1	2	2,50

Rated operational power				
Utilization category	Voltage (V)	No. of phases	No. of poles	Power (kW)
AC-23A	220 - 240	1	2	5,50
AC-23A	380 - 440	1	2	11
AC-23A	500 - 500	1	2	15
AC-23A	660 - 690	1	2	10

Max. Fuse rating IEC			
Fuse characteristic	No. of Fuses	Current (A)	
gG	1	63	

UL60947-4-1 , UL508

Rated insulation voltage Ui		
Voltage (V)	AC / DC	
600	AC	

Rated thermal current			
Current (A)	Ambient temperature (°C)	Additional Text	
55	0 - 40	-	

GENERAL TECHNICAL INFORMATION


Tightening torque of screws		
tightening torque (Nm)	tightening torque (lb-in)	
1,80	16	

Rated short-time withstand current Icw		
Time (s)	Current (A)	
1	950	

Size of conductor				
composition of conductor	Min. / Max. value	No. of conductor per terminal	Cross section (mm ²) or (AWG/kcmil)	Material of the wire
Solid wire	Min.	2	0.75mm ²	Copper
Solid wire	Min.	1	1.5mm ²	Copper
Flexible wire	Max.	1	AWG 6	Copper
Flexible wire	Min.	1	2.5mm ²	Copper
Flexible wire	Max.	1	10mm ²	Copper
Flexible wire	Min.	2	1.5mm ²	Copper
Single-core or stranded wire	Max.	1	AWG 6	Copper
Single-core or stranded wire	Max.	1	16mm ²	Copper
Flexible wire with ferrule according to DIN 46228	Min.	2	0.75mm ²	Copper
Flexible wire with ferrule according to DIN 46228	Max.	1	10mm ²	Copper
Flexible wire with ferrule according to DIN 46228	Min.	1	1.5mm ²	Copper

Approbations	
Specification	Marking

EAC 

CE marking 

UK Directives
IEC 60947-3; EN 60947-3; VDE 0660 Teil107 **IEC 60947-3
EN 60947-3**

UL 60947-4-1; CSA C22.2 No. 60947-4-1 

Power loss per pole	
Power (W)	
1,80	

Conditions during transport and storing			
Minimum temperature (°C)	Maximum temperature (°C)	additional requirements	
-40	85	In case of temperatures below -5°C no shock load permissible	

Shock / Vibration	
Type of oscillation	Values
Resistance to shock	min. 5g, 30ms
Resistance to vibration	IEC 61373 (1999) Category 1, Class B

General Information	
Text	

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.

General Information**Text**

- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
- After wiring, ALL terminal screws must be tightened to the specified torque values.
- The protection class of the selected mounting type may vary if optional extras are used.
- Do not lubricate or treat contacts.
- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.
- After installation of the switches the spacings between the terminals must be sufficient to fulfill the requirement of the applicable standards.

Operating temperature*Min. Temperature [°C]*

-25

Max. Temperature [°C]

60