



Sample image

KG32

Type Size: S00

Classification Contact: Rigid contact bridge

Classification Contact Mat: Silver


Classification Terminal: Screw terminal

| ated insulat | tion voltage Ui | | | | | | |
|------------------|-----------------------------|-----------------------|---|-----------------------------------|--------------------------|----------|------------------------------|
| | | | Voltage (| (V) AC/DC | | | |
| | | | 6 | 90 AC | | | |
| | e withstand voltage Uimp | | | | | | |
| Voltage | e (kV) Overvoltage cate | gory Pollution | degree Supply sy | stem | | | Function |
| | 6 III | 3 | Valid for I | ines with grounded common neutral | termination | | Switch / Switch disconnector |
| Rated uninte | rrupted current lu/lth | | | | | | |
| <u> </u> | | | Peak temperature (°C) | additional requirements | | | |
| 32 50 | | 55 | | | | | |
| | enclosed thermal curren | t Ithe | | | | | |
| Current (A) | Ambient temperature (°C) | Peak temperature (°C) | Additional requirements | No. | of stages (from - to) | Mounting | Mounting size |
| 32 | 35 | 40 | Ambient temperature +35°C peaks up to +40°C | C during 24 hours with | - | - | |
| Rated operat | ional current le | | peake up to 110 c | | | | |
| Jtilization ca | | | | Voltage (V) | | | Current (|
| AC-32A | | | | 20 - 400 | | | |
| AC-20A | | | | 690 | | | ; |
| AC-21A | | | | 20 - 690 | | | ; |
| AC-22A | | | | 220 - 500 | 220 - 500 | | |
| AC-22A | | | | 660 - 690 | ; | | |
| Rated operat | ional power | | | | | | |
| Jtilization ca | tegory | | Voltage (V) | No. of phases | No. o | of poles | Power (kl |
| /C-3 | | | 220 - 240 | 3 | | 3 | 5, |
| AC-3 | | | 380 - 440 | 3 | | 3 | 7, |
| AC-3 | | | 500 - 500 | 3 | | 3 | 7, |
| AC-3 | | | 660 - 690 | 3 | | 3 | 7, |
| AC-3 | | | 220 - 240 | 1 | | 2 | - |
| AC-3 | | | 380 - 440 | 1 | | 2 | 5, |
| AC-23A | | | 220 - 240 | 3 | | 3 | 5, |
| AC-23A | | | 380 - 440 | 3 | | 3 | |
| AC-23A AC-23A | | | 500 - 500 660 - 690 | 3 | | 3 | |
| AC-23A AC-23A | | | 220 - 240 | 1 | | 2 | 4,2 |
| AC-23A | | | 380 - 440 | 1 | | 2 | 7,5 |
| Max. Fuse ra | ting IFC | | 300 - 440 | | | 2 | 7,0 |
| use characte | | | | | No. of Fuses | | Current (|
| јG | | | | | 1 | | |
| JL60947- | 4-1 , UL508 | | | | | | |
| Rated insulat | tion voltage Ui | | | | | | |
| | | | Voltage (| (V) AC/DC | | | |
| | | | 6 | 00 AC | | | |
| Rated therma | al current | | | | | | |
| | | Current (A) | | Ambient temperature (°C) | Additional Text | | |

⁻ The operating handle and position indicating means to be used with these manual motor controllers should be provided from the manufacturer, or the operating handle and position indicating means to be used should have been previously evaluated in combination with the manual motor controllers.



| CSA | | | | | | |
|---|-------------------|----------------|---------------------------|---------------------------------------|-----------------|---|
| | | | | | | |
| Rated insulation voltage Ui | | Voltage (V) | AC/DC | | | |
| | | 600 | AC | | | |
| Rated thermal current | | | | | | |
| | Current (A) | | Ambient temperature | (°C) Additional Text | | |
| | 30 | | 0 | - 40 | | |
| GENERAL TECHNICAL INFORMATION | | | | | | |
| Tightening torque of screws | | | | | | |
| | tighteni | ng torque (Nm) | | | tighte | ning torque (lb-i |
| Date dalamat time with standary want law | _ | 1,25 | _ | _ | | |
| Rated short-time withstand current lcw | | Time (s) | | | | Current (|
| | | 1 | | | | 4: |
| Size of conductor | | | | Orace section (mm²) as | | |
| composition of conductor | Min. / Max. value | No. | of conductor per terminal | Cross section (mm²) or (AWG/kcmil) | Material of the | wire |
| Solid wire | Min. | | 1 | 0.75mm² | Copper | |
| Solid wire | Min. | | 2 | 0.5mm² | Copper | |
| Flexible wire | Min. | | 2 | 0.75mm² | Copper | |
| Flexible wire | Max. | | 1 | AWG 10 | Copper | |
| Flexible wire | Max. | | 1 | 4mm² | Copper | |
| Flexible wire | Min. | | 1 | 1.5mm² | Copper | |
| Single-core or stranded wire | Max. | | 1 | 6mm² | Copper | |
| Single-core or stranded wire | Max. | | 1 | AWG 10 | Copper | |
| Flexible wire with sleeve | Max. | | 1 | 4mm² | Copper | |
| | Min. | | | 0.75mm ² | Copper | |
| Flexible wire with ferrule according to DIN 46228 Approbations | Min. | _ | 1 2 | 0.5mm² | Copper | Madrina |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification | | _ | | | | Marking |
| Flexible wire with ferrule according to DIN 46228 Flexible wire with ferrule according to DIN 46228 Approbations Specification EAC | | _ | | | | Marking EHI |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification | | | | | | |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification EAC | | | | | | EAC |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification EAC CE marking UK Directives | | | | | | EAC |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification EAC CE marking | | | | | | EAC |
| Flexible wire with ferrule according to DIN 46228 Approbations Specification EAC CE marking UK Directives | | | | | | EHI CE Lloyds Register IEC 60947- |
| Approbations Specification EAC CE marking UK Directives Lloyd's Register EMEA IEC 60947-3; EN 60947-3; VDE 0660 Teil107 | | | | | | Lloyds Register IEC 60947- EN 60947- |
| Approbations Specification EAC CE marking UK Directives Lloyd's Register EMEA | | | | | | EHL C E Lloyds Register IEC 60947- |
| Approbations Specification EAC CE marking JK Directives Lloyd's Register EMEA EC 60947-3; EN 60947-3; VDE 0660 Teil107 JL 60947-4-1; CSA C22.2 No. 60947-4-1 | | | | | | Lloyds Register IEC 60947- EN 60947- |
| Approbations Specification EAC CE marking UK Directives Lloyd's Register EMEA | | | | | | LIOVAS REGISTER IEC 60947- EN 60947- USTED7/B7 |
| Elexible wire with ferrule according to DIN 46228 Approbations Specification EAC DE marking JK Directives Lloyd's Register EMEA EC 60947-3; EN 60947-3; VDE 0660 Teil107 JL 60947-4-1; CSA C22.2 No. 60947-4-1 CSA C.22.2 No.14 GB/T14048.3 | | | | | | LIDVAS REGISTER LIEC 60947-EN 60947- EN 60947- GU US GETTIGHAS. |
| Approbations Specification EAC CE marking JK Directives Lloyd's Register EMEA EC 60947-3; EN 60947-3; VDE 0660 Teil107 JL 60947-4-1; CSA C22.2 No. 60947-4-1 CSA C.22.2 No.14 GB/T14048.3 Russian Maritme Register of Shipping | | | | | | Lloyds Register IEC 60947- EN 60947- |
| Elexible wire with ferrule according to DIN 46228 Approbations Expecification EAC DE marking JK Directives Lloyd's Register EMEA EC 60947-3; EN 60947-3; VDE 0660 Teil107 JL 60947-4-1; CSA C22.2 No. 60947-4-1 CSA C.22.2 No.14 SB/T14048.3 | | | | | | LIDVAS REGISTER LIEC 60947-EN 60947- EN 60947- GU US GETTIGHAS. |





| Shock / Vibration | |
|-------------------------|-------------------------|
| Type of oscillation | Values |
| Resistance to vibration | Min. 4g, 2-100Hz, 1,6mm |
| Resistance to shock | min. 6g, 6ms |
| General Information | |

Text

- Use only copper wires with or without tinned/silver-plated individual wires. Soldering the end of the wire before wiring is not allowed.
- EMC Note: This device is suitable for use in environment A and B.
- Terminals with factory fitted jumper links are tightened during production for loss prevention. When opening the terminal clamps, make sure that no factory fitted links get lost and that all wire connections are properly seated.
- After wiring, ALL terminal screws must be tightened to the specified torque values.
- The protection class of the selected mounting type may vary if optional extras are used.
- Do not lubricate or treat contacts.
- Switches may only be mounted, connected and set into operation by qualified persons according to the accepted rules of technology.

| Operating temperature | |
|-----------------------|-----------------------|
| Min. Temperature [°C] | Max. Temperature [°C] |
| -5 | 55 |